



Certificate of Compliance

Certificate: 2084223

Master Contract: 242006

Project: 2179442

Date Issued: 2009/07/09

Issued to: EMO3 (4170415 Canada Inc.)

180 Montée de Liesse
St-Laurent, QC H4T 1N7
Canada
Attention: Richard Haché

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Gabriel Raymond, ing.

Authorized by: Helene Vaillancourt, Operations Manager

PRODUCTS

CLASS 1211 01 COMFORT CONDITIONING EQUIPMENT - Air Cleaners - Electrostatic

CLASS 1211 81 COMFORT CONDITIONING EQUIPMENT - Air Cleaners - Electrostatic - Certified to U.S. Standards

Ozone generator (Oxygen activated) for commercial and industrial use, plenum mounted, Series EMO3-XYZ, 120V ac, 60 Hz, 5 Amp. Max., cord/plug connected.



Certificate: 2084223

Master Contract: 242006

Project: 2179442

Date Issued: 2009/07/09

Note : Suffixes (XYZ) are added to the above catalogue numbering to denote the following characteristics :

- X = The quantity of ozone generator cells (fittings or Ozone generator cannons), 1, 2 or 3

- Y = Size of Enclosure : 1 = small, 2 = medium, 3 = large

- Z = Supply Voltage : 1 = 120 V ac.,

Example : EMO3-331, 3 cannons, in a large enclosure, at 120 V ac.

Certified only against electric shocks and fire hazards.

APPLICABLE REQUIREMENTS

C22.2 No. 187-M1986 (R2003) Electrostatic Air Cleaners (used as a guide)

Technical Information Letter No. H13B Commercial Use Air Cleaners Designed to Produce Ozone
(used as a guide whenever applicable)

Technical Information Letter No. H13A Commercial Use Air Cleaners Designed to Produce Ozone, Interim
Certification Requirements for Ozone Generators Used in Unoccupied
Space. (used as a guide whenever applicable)

ANSI/UL 867 Electrostatic Air Cleaners (used as a guide)